



THE CITY OF SAN DIEGO

Fire-Rescue Department

Sprinkler Policies

Policy FS - 0407

Exposed Sprinklers

All sprinklers installed in exterior locations, such as beneath canopies, porches, balconies, or in open parking garages shall be listed or approved as corrosion resistant. In addition, such heads shall be installed within 20 feet of any opening in enclosed garages.